

## Standard Use, Care & Cleaning Instructions

Acran acoustic louvres are designed to provide an aesthetic appearance while controlling noise and allowing passage of air. Once installed it is important to ensure the louvres are not damaged as this may affect both their acoustic and airflow performance.

In the event that a louvre is damaged, Acran should be consulted to ensure the louvre is repaired in an appropriate manner and without compromising the properties of the louvre.

Acran Acoustic Louvres are manufactured from both solid and perforated galvabond. The louvres are filled with an inert non-combustible acoustic grade absorber.

The products can be supplied with a variety of finishes however the cleaning process for all finishes is identical.

The louvres may, over time begin to collect dust and grime due to their location and exposure to varying weather conditions. The louvres should be cleaned to refresh their visual appearance at six monthly intervals.

In coastal or industrial environments cleaning should be carried out more frequently paying particular attention to areas that are not normally washed by rain.

Galvabond louvres are not designed to be used in areas where they may be exposed to contaminants such as water treatment or cleaning chemicals. If the louvres are exposed to such contaminants they should be cleaned immediately to reduce the detrimental impact of the chemicals.

Cleaning of the louvres should be completed using a soft, clean cloth and Meguiars Soft Wash Gel cleaner. The cleaning process and quantities must be in accordance with the manufacturer's instructions. Surfaces should be thoroughly rinsed with fresh water after cleaning.

**DO NOT** use harsh cleaning fluids, strong solvents or abrasive cleaning materials, as these will damage the surface finish on the acoustic louvres. Once the louvre surface finish is damaged it cannot be repaired and in many cases may lead to deterioration of the base metal.

This instruction sheet is available in electronic format.

Rev 01/06